



NOTES:

1. Do not scale drawing.
2. Dimensions are in inches (mm).
3. LHR door shown. Preparation is typical for both door hands.
4. Minimum door stile width: 4-1/2(114).
5. Prepare mounting holes when installing the device.
6. Unreinforced frames require blind rivet nuts (by others) to mount the strike.
7. Dimension from door face.
8. Provide adequate structural support to maintain door integrity after device installation with power tools, door use, or abuse.
9. Device mount to hinge stile (not shown) requires hole location and preparation during device installation. Door structural requirements are similar for both door stiles.
10. For outside trim preparation see appropriate trim template.
11. This hole MUST be field located using physical part as template, after installation is complete and device is fully operational.
12. Cutout, 1/2 (13) deep, only required when active outside trim is used.
13. Wood screws (#14x1-1/2"RHWS, by others) permitted for solid core wood doors if pilot holes are used for installation.



MULLION NOTE:

FOR MULLION MODEL NUMBERS M100(F) AND KRM100(F)
REFER TO TEMPLATE NUMBER 7400-0100.

FOR MULLION MODEL NUMBERS M200(F) AND KRM200(F)
REFER TO TEMPLATE NUMBER 7400-0200.

FOR MULLION MODEL NUMBERS M200FWS AND
KRM200FWS REFER TO TEMPLATE NUMBER 7400-0210.

RESPONSIBILITY

DOOR AND FRAME MANUFACTURERS ARE RESPONSIBLE FOR PROVIDING ADEQUATE CONSTRUCTION OR REINFORCEMENTS FOR PROPER INSTALLATION OF HARDWARE SHOWN. ALL ARCHITECTURAL BUILDERS HARDWARE MUST BE INSTALLED ON PROPERLY REINFORCED DOORS AND FRAMES, REGARDLESS OF TYPE, MATERIAL, OR METHOD OF CONSTRUCTION.

1500 Rim Panic Devices with 799 Strike & Optional SNB

Application for Wood or Composite Door and H.M. Frame or Mullion (Not for Fire Labeled Devices)

Contact us for support at 1-855-557-5078.

ASSA ABLOY

SUPERSEDES	02/08	DO NOT SCALE DRAWING
TEMPLATE NUMBER	7415-1000	DATE 12-23