



Right Hand Shown

Notes:

- Do not scale drawing.
- Right hand door shown. Same dimensions apply for left hand door, measured from centerline of hinge or pivot.
- Template information based upon use of 4-1/2" hinges or 3/4" offset pivots.
- Dimensions are shown in inches and millimeters (mm).
- Hollow metal doors require channel or box-type reinforcement when thru-bolt mount is specified.
- Sex-nuts are required for wood or plastic faced fire-door installations.
- Minimum thickness recommended for reinforcements in hollow metal doors and frames is .1046 (2.66) unless noted otherwise.
- Minimum ceiling clearance for closer unit is 2" (50).
- Maximum door opening is 105°.
- Charted dimensions measured from door rabbet.

Frame Type	Dim. "A"	Dim. "B"	Dim. "C"
Single Step	1-3/8 (39)	1-7/16 (37)	1-1/4 (32)
Double Step	1-1/4 (32)	1-5/8 (41)	1-7/16 (37)

Preparation for Fasteners			
	Fasteners	Door or Frame	Drill-Sizes
Standard	1/4" - 20 machine screw	Metal	Drill: #7 (0.201" dia.) Tap: 1/4" - 20
	Sleeve nuts and bolts	Hollow Metal	9/32" (7 mm) through; 3/8" (9.5 mm) door face opposite to closer
Aluminum or Wood		3/8" (9.5 mm) through	
Optional	Through-bolts and grommet-nuts	All	9/32" (7 mm); 3/8" (9.5 mm) dia. x 3/8" (9.5 mm) deep on door opposite to closer

Yale Series 400PTO-DE Support Unit

For Installations with a Double Egress Frame

Combination Door Closer-Holder with Single Point Hold Open

Hinge (Pull) Side of Door Installation with Hinge Side Frame Reveals 1/8" to 3" (3 to 76mm)

1-800-438-1951



www.yalecommercial.com

TEMPLATE NUMBER **7348-1811** DATE **02-09**