



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3725-0684:0107
CATEGORY:	3725 - DOOR HARDWARE (FIRE-RATED)
LISTEE:	ADAMS RITE MFG 10027 S. 51st St., Ste. 102, Phoenix, AZ, 85044 Contact: Peabody, Josh (623) 582-4626 (909) 632-2369 Email: josh.peabody@assaabloy.com
DESIGN:	Series 3300 consists of a single point mortise latch and a push bar assembly. Series 3300 may have suffixes ELR, M and/or SE. The maximum size of a single door is 4' wide x 8' high and a pair of doors is 8' wide x 8' high. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Series 3300: suitable for 3/4, 1-1/2, and 3 Hr. metal fire doors
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating and UL label.
APPROVAL:	Listed as fire exit hardware for use with single door only. Refer to listee's Installation Instruction Manual for details.
NOTES:	

09-12-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/14/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division