



Notes:

1. Minimum Stile Width 4-1/2(114).
2. For door reinforcements see template T30800. Unreinforced doors require optional SNB to mount devices.
3. Unless otherwise specified, door preparation and dimensional tolerances must conform to ANSI A115.1. Lock support required as shown.
4. For outside trim preparation see appropriate trim template.
5. Prepare mounting holes when installing the device.
6. LHR active pair shown. Preparation is typical for both door hands.
7. Dimensions are in inches (mm). Do not scale drawing.
8. Holes for optional SNB: 9/32(7.00)Dia. inside door face; 3/8(9.50) Dia. outside door face.
9. Dimensions given about a centerline are symmetrical.
10. Device mount to hinge stile (not shown) requires holes location and preparation during device installation.
11. For Electrical device suffixes "-Safe", "-Secure", M91, or M93: 1/2 (12.70) diameter, this face, plus prep shown on template T30890.
12. For electrical device suffixes M92, M94 or M97 also see template T30890.
13. Latchbolt centerline is 23/32 (18.2) below & Auxbolt centerline is 3/16 (4.8) above the centerline of lockfront.

**ED5602 & ED5602A Series Double Cylinder Mortise Exit Devices
with ANSI A115.1 Strike**
Application for Pair of Metal Doors without Mullion

**Corbin
Russwin**[®]
www.corbinrusswin.com

SUPERSEDES	DO NOT SCALE DRAWING
TEMPLATE NUMBER	DATE

T30978 **8-03**