



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3774-0923:0102
CATEGORY:	3774 - ELECTRIC LOCKS
LISTEE:	Securitron Magnalock 10027 S. 51st St., Ste. 102, Phoenix, AZ, 85044 Contact: Peabody, Josh 6235824626 Email: josh.peabody@assaabloy.com
DESIGN:	Models EXD-1 and EXD-1F exit delay systems. Unit consists of the following subassemblies: BPS-12, -1, -3, -4.5, -6, -9, -15, BPS-24, -1, -2, -3, -4, -6, -10, BPSM-12, -6, -9, -15, BPSM-24-4, -6, or -10 Class 2 Output Power Supplies; MK or MKN Mortise Keyswitch; TSB-1, TSB-3, TSB-3B, 3100, 3300, 3600, 3700, LMS-1, LML-1, -2, TSH-BK, -CL, MXD-32, -62 exit device, TDM, TDMT, XDT logic timers and Series 32, 34, 38, 62, 68, 82, and SAM Series Locking Devices, and LCP Lock Control Panel. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Input: 120VAC, Output: 12 or 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as electric special egress-control device. Model EXD-1 is intended for installation on non-fire rated doors. Model EXD-1F is intended for installation on wood or metal fire rated doors. Authority having jurisdiction shall be consulted prior to installation.
NOTES:	Both models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is NOT approved.

Updated 08-05-10
fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Date Issued: 03/14/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division