



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3774-0923:0103
CATEGORY:	3774 - ELECTRIC LOCKS
LISTEE:	Securitron Magnalock 10027 S. 51st St., Ste. 102, Phoenix, AZ, 85044 Contact: Peabody, Josh 6235824626 Email: josh.peabody@assaabloy.com
DESIGN:	<p>Models XP-1 and XP-1F exit locking system. System consists of the following subassemblies:</p> <p>BPS-12, -1, -3, -4.5, -6, -9, -15; BPS-24, -1, -2, -3, -4, -6, -10; BPSM-12-6, -9, -15; or BPSM-24-4, -6, -10 Class 2 output power supplies</p> <p>TSB-1, TSB-3, or XMS exit device (XP-1F requires 3100, 3300, 3600, 3700)</p> <p>Series 32, 34, 38, 62, 68, and 82 or SAM Series locking device</p> <p>Models TSH-BK and TSH-CL Touch Sense Handle exit device</p> <p>LCP Lock Control Panel</p> <p>Refer to listee's data sheet for detailed product description and operational considerations.</p>
RATING:	Input: 120 VAC, Output: 12 or 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as electric locking system. Model XP-1 is intended for installation on non-fire rated doors. Model X-1F is intended for installation on wood or metal fire rated doors. Authority having jurisdiction shall be consulted prior to installation.
NOTES:	Both models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is NOT approved.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

*Rev. 04-19-2005



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/14/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division