

CM-222

Touchless Exit Switch with Remote LED Triggering

INSTALLATION INSTRUCTIONS

PARTS INCLUDED IN THE BOX

- (1) CM-222
- (1) Parts bag (Contents: (2) 6-32 X 1/2" oval head Phillips ss screws, (2) 6-32 X 1/2" snake eye s/s flat head screws, (1) Key for tamper proof screws (snake eye), (1) Jumper for factory external LED control)
- (1) User/Installation Manual
- (1) Faceplate Gasket



1. GENERAL DESCRIPTION

The CM-222 Hands-Free Switch uses active infra-red microburst sensor technology, designed for use in ADA compliant automatic door control applications and access control.

The CM-222 switches eliminate the spread of germs by avoiding physical contact, and provide greater convenience when moving through the premises. The switches are available with stainless steel faceplates, in narrow (jamb), single gang or double gang configurations.

All models are ROHS compliant with lead-free construction. Built-in remote LED switching allows for integration with third-party applications, such as guard and nurse station annunciators. Adjustable time delay from 0.5 to 20 seconds and an adjustable range from (2" to 8" / 5cm to 20cm).

2. SPECIFICATIONS

Voltage	12 to 24 VDC +/- 10%
Current	45 mA (peak)
Contact Rating	1 Amp @ 30 VDC
Contacts	Common/ N.O./ N.C.
Temperature Range	14F to 122F (-10 to 50 °C)
Response Time	10ms

NOTE: Do NOT use AC Voltage for this unit. Please see section 8 for power requirements

Dimensions	Narrow: 1 3/4" W x 4 1/2" H x 1 1/4" D (43 mm x 114 mm x 31 mm)
	Single Gang: 2 3/4" W x 4 1/2" H x 1 1/4" D (70 mm x 114 mm x 31 mm)
	Double Gang: 4 1/2" W x 4 1/2" H x 1 1/4" D (114 mm x 114 mm x 31 mm)

3. FEATURES

- Built-in Blue and Green LED indication. Factory default = Blue (Standby), Green (Triggered)
- Blue and Green LEDs can be controlled by sensor or externally
- Adjustable detecting distance: 2 to 8 Inches (5 cm to 20 cm)
- Adjustable Time Delay: 0.5 seconds to 20 seconds
- Toggle function selection available
- IP65 rating
- IR lens to provide stable and reliable operation

4. OPERATION AT A GLANCE

In a typical application, as you approach the CM-222, the LED will be blue. When you wave your hand in front it will change the LED to green, and trigger its relay to change state and unlock your door, or trigger the door operator to open the door. The toggle feature can be used to trigger the door to remain in the unlocked position, until you wave your hand a second time to relock it.

CM-222 TOUCHLESS EXIT SWITCH WITH REMOTE LED TRIGGERING

INSTALLATION INSTRUCTIONS

5. CONFIGURING THE CM-222

Range of Detection and Output Duration

Looking at the back of the CM-222 with the Mode pins located at the top, you will see two adjustment potentiometers. The one on the left can be turned clockwise to set the range of detection (2" to 8" / 5cm to 20cm), and the one on the right will set the duration of the output (0.5 to 20 seconds).

If the output needs to be triggered and maintained in that state until triggered once more, then the Toggle feature can be used by turning the output duration adjustment potentiometer to the fully clockwise position.


Remote LED Switching

The CM-222 can also have its LED states controlled remotely. This is done by installing the supplied jumper from the parts bag onto the two pins on the back of the unit. Once installed the green and blue LED's can be triggered to change by bringing either one low (to ground). The yellow wire controls the green LED, whereas, the white wire controls the blue LED. They can be individually turned on or off, or they can be wired to a SPDT contact to turn blue on and green off, or vice versa.

MODE PINS:

OPEN (Default position)=
Internal mode where the LED
colours will be controlled by
the IR sensor.


SHORTED = External mode
where the LED colours will be
controlled by Yellow and
White wires.



6. WIRING THE CM-222.

1. Connection to a Door Operator


Connect the two trigger wires from the door operator to the blue and green wires on the CM-222. Then, connect the black wire of the CM-222 to the ground (-) of VDC power supply. Next, connect the red wire of the CM-222 to the positive (+) of the VDC power supply. Adjust to your needed range and output duration, using the potentiometers located on the back of the CM-222.



#	Color	Function
1	Red	12 to 24 VDC
2	Black	0 VDC (Ground)
3	Yellow	Green LED controlled by external mode.
4	White	Blue LED, controlled by external mode.
5	Green	Relay: Normally Open
6	Blue	Relay: Common
7	Purple	Relay: Normally Closed

2. Connection to a Maglock

Connect the ground (-) of the maglock to the ground (-) of VDC power supply. Next, connect the positive (+) of the maglock to the blue wire (common) of the CM-222, then connect the purple wire (normally closed) to the positive (+) of the VDC power supply. Then, connect the black wire of the CM-222 to the ground (-) of VDC power supply. Next, connect the red wire of the CM-222 to the positive (+) of the VDC power supply. Adjust to your needed range and output duration using the potentiometers located on the back of the CM-222.




#	Color	Function
1	Red	12 to 24 VDC
2	Black	0 VDC (Ground)
3	Yellow	Green LED controlled by external mode.
4	White	Blue LED, controlled by external mode.
5	Green	Relay: Normally Open
6	Blue	Relay: Common
7	Purple	Relay: Normally Closed

CM-222 TOUCHLESS EXIT SWITCH WITH REMOTE LED TRIGGERING INSTALLATION INSTRUCTIONS

3. Connection to an External Strike


Connect the ground (-) of the strike to the ground (-) of VDC power supply. Next, connect the positive (+) of the strike to the blue wire (common) of the CM-222, then connect the green wire to the positive (+) of the VDC power supply. Then, connect the black wire of the CM-222 to the ground (-) of VDC power supply. Next, connect the red wire of the CM-222 to the positive (+) of the VDC power supply. Adjust to your needed range and output duration, using the potentiometers located on the back of the CM-222.



4. Connection to any Device using External LED Control

After using one of the typical wiring layouts as described above for any normally open or closed device you can now set up the remote LED triggering of the CM-222.


The red and green LED control wires will be wired through a SPDT (single pole double throw) contact. First, determine which color will be on and which color it will be switched to when remotely triggered. If you would like red to be on as the default, then connect the white wire from the CM-222 to the normally closed pole of the remote contact doing the switching. Then, connect the yellow wire to the normally open pole of the SPDT contact. Next, connect the common pole of the SPDT contact to the VDC ground of the VDC power supply being used. When the remote triggering system changes its contact, it will disconnect the white wire from the VDC ground and turn it off. At the same time, it will switch the yellow wire to ground turning on the green LED. If the opposite colors need to be switched then simply reverse the white and yellow wires on the contact.



7. POWER


The CM-222 is a **VDC device only** and will accept a range of VDC power from 12VDC to 24VDC (+/- 10%). *Do not connect AC voltage to the CM-222 at any time.*

Note: A linear output VDC power supply is strongly recommended. If using power from other than Camden's CX-PS13 filtered regulated power supply, you must measure the provided power before applying power to the CM-222. Voltages of more than 10% over the specified acceptable range or using a power supply with large amounts of AC voltage on it (**unfiltered unregulated power such as a transformer and a rectifier**) may damage the CM-222 and void the warranty.



CM-222 TOUCHLESS EXIT SWITCH WITH REMOTE LED TRIGGERING

INSTALLATION INSTRUCTIONS



FACEPLATE GRAPHIC OPTIONS	
-xxx =	DESCRIPTION
-42	Hand Icon, "Wave to Open" text and Wheelchair Symbol
-42F	Hand Icon, "Wave to Open" text and Wheelchair Symbol, French
-A42	Hand Icon, "Wave to Open" text and Active Wheelchair Symbol
-A42F	Hand Icon, "Wave to Open" text and Active Wheelchair Symbol, French
-46	Hand Icon, and "Wave to Exit".

ORDERING INFORMATION FOR REPLACEMENT PARTS

ITEM NUMBER	PART NUMBER	DESCRIPTION
1.	60-31A083	TOUCHLESS SENSOR SWITCH WITH EXTERNAL LED CONTROL
2.	A 60-49B040-xxx	NARROW STAINLESS-STEEL FACEPLATE
	B 60-49H009L-xxx	SINGLE GANG STAINLESS-STEEL FACEPLATE
	C 60-49C058-xxx	DOUBLE GANG STAINLESS-STEEL FACEPLATE
3.	A 60-59H000	GASKET FOR NARROW GANG TOUCHLESS SWITCH
	B 60-59H001	GASKET FOR SINGLE GANG TOUCHLESS SWITCH
	C 60-59H003	GASKET FOR DOUBLE GANG TOUCHLESS SWITCH

PARTS KIT

ITEM NUMBER	PART NUMBER	DESCRIPTION
4.	60-34B093	(A) 6-32 X 1/2" OVAL HD PHILLIPS SS SCREW (B) 6-32 X 1/2" SNAKE EYE SCREW (C) KEY FOR TAMPER SNAKE EYE SCREW

COMPATIBLE MOUNTING BOXES OPTION

ITEM NUMBER	PART NUMBER	DESCRIPTION
	FOR SINGLE GANG	
	CM-34AL	SURFACE BOX, STANDARD DEPTH, THREADED CONDUIT ENTRY. HEAVY DUTY CAST ALUMINUM 2 3/4"W x 4 1/2"H x 1 3/4"D (70mm x 114mm x 45mm)
	CM-34BL	ONE GANG BLACK ABS BOX, SURFACE MOUNT 2 7/8"W x 4 5/8"H x 1 3/4" D (73mm x 117mm x 44mm)
	CM-66	FLUSH BOX & DRESS PLATE, STANDARD DEPTH BOX WITH 7" x 7" (178mm x 178mm) DRESS PLATE HEAVY GAUGE STAINLESS STEEL
	FOR MULLION	
	CM-23D	SURFACE BOX WITH EXTRA DEPTH, FLAME, AND IMPACT RESISTANT BLACK POLYMER (ABS) 1 3/4" W X 4 1/2"H X 1 3/4"D (46MM X 117MM X 43MM)
	FOR DOUBLE GANG	
CM-53	SURFACE BOX WITH STANDARD DEPTH DOUBLE WALL, FLAME/IMPACT RESISTANT BLACK POLYMER (ABS) 4 1/2"W X 4 1/2"H X 2"D (115MM X 115MM X 51MM)	